




The State of New Hampshire
Department of Environmental Services



Michael P. Nolin
Commissioner

April 14, 2006
Letter of Compliance
For
Letter of Deficiency
DSP #06-006

Mr. Douglas Holler
General Manager
Trustees of Dartmouth College
Dartmouth College
14 South Main Street, Suite 2C
Hanover, NH 03755

Re: Dartmouth Skiway Sewage Lagoon Dam #146.45 in Lyme
Letter of Deficiency (LOD) DAM #146.45
Issued on February 2, 2006

Dear Mr. Holler:

Based on a file review and a follow-up inspection conducted on April 10, 2006 of the above referenced dam, the Department of Environmental Services (DES) has determined that the referenced LOD is considered complete and will be closed. Enclosed is a copy for your reference. Additionally, the following was observed at the time of the aforementioned inspection:

1. Large trees were removed, however brush remained on the north and east downstream embankments.
2. A rodent hole was observed along the fence line at the middle of the east embankment. The rodent hole was several feet deep heading toward the water surface within the impoundment.

The Department of Environmental Services is requesting that you establish a schedule that will allow for brush removal on a yearly basis. DES is also requesting that you fill the rodent hole with properly compacted earth embankment fill, (see attached specifications), by June 1, 2006. If you have any questions or comments, please contact me at 603-271-3406 or write to the Water Division at the address listed below.

Sincerely,

COPY
Dale F. Gunn, P.E.
Dam Safety Engineer

Enclosure: Copy of February 2, 2006 LOD, Soil Specifications

cc: Gretchen R. Hamel, Legal Unit Administrator ✓
Town of Lyme

DFG/h:/safety/wendy/lod/14645compltr.doc